

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

September 13, 2013

GLACIER WATER SERVICES INC. VICKI DONATI 1385 PARK CENTER DR VISTA CA 92081

Re: Description: WATER TREATMENT DEVICE - BOTTLED WATER VENDING MACHINE

Manufacturer: GLACIER WATER SERVICES INC.

Product Name: GLACIER WATER

Model Number(s): 2097 AND M2 BOTH USING THE GW PROCESSING TOWER

Product File No: 20130114

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2018.

This approval supersedes the approval issued on June 27, 2008 under product file number 20070174.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those
 contaminants and/or substances as specified in this approval letter when the product is installed and maintained
 in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If this approved device is modified or additional assertions of function or performance are made, then this
 approval shall be considered null and void, unless the change is submitted to the department for review and the
 approval is reaffirmed.
- The system shall be provided with an in-line total dissolved solids (TDS) monitor, or other acceptable means, to warn the user when the system is not performing its functions. Acceptable alternatives to an in-line TDS monitor include:
 - 1. terminating the discharge of treated water;
 - 2. sounding an alarm which is connected to acceptable power source;
 - 3. flashing a light connected to an acceptable power source;
 - 4. providing the user with an obvious, readily interpretable, indication of the system's ability to perform (e.g. decreasing the flow rate of treated water by 50% or more for systems making mechanical filtration claims;

SBD-10564-E (N.10/97) File Ref: 13011401.DOC

Glacier Water Services Incorporated September 13, 2013

Page 2 of 2

Product File No.: 20130114

(continued from previous page)

- 5. providing a sampling service by the manufacturer, either directly or through an authorized dealer, a minimum of once every six months;
- 6. providing a sampling kit for analysis of TDS or other appropriate contaminants; or
- 7. providing a TDS monitor to measure the product water quality.

Whichever means of performance verification is selected, it shall be clearly described in the owner's manual for this device, and approved for use along with the device.

Based on testing data submitted to and reviewed by the department, this approval recognizes that this plumbing product will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

AESTHETIC CONTAMINANT REDUCTION CAPABILITIES PRODUCT FILE NUMBER 20130114 TABLE 1 OF 1

Flow Rate: 1,012 gallons per day (gpd)

Tested Contaminant	Influent Challenge (mg/l) ¹
Total Dissolved Solids (NaCl)	466

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted in accordance with National Automatic Merchandising Association (NAMA) "Standard for the Sanitary Design and Construction of Food and Beverage Vending Machines". To qualify for total dissolved solids (TDS) reduction performance, the device must reduce the influent challenge concentrations such that the TDS concentration of the treated water effluent is ≤ 10 mg/l.

1 = milligrams per liter (mg/l) are equivalent to parts per million (ppm)

≤ = less than or equal to

 \pm = plus or minus

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail